सत्यमेव जयते

Goverment of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services

First Floor of Midnapur Fire Station Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo No.:FSR/WBFES/HOW/700/15 **Date : 19-12-2025**

From :
Divisional Fire Officer
Paschim Medinipur,
West Bengal Fire & Emergency Services

To :
DHYANESWAR SUBODH ACADEMY
VILL-GOGRAS COURT TALUK PO-RAGHUNATHBARI PS-PANSKURA DIST-PURBA MEDINIPUR PIN-721634

Sub : Fire Safety Certificate for an existing G+IV (Block-B as per plan) storied building in the name & style of "DHYANESWAR SUBODH ACADEMY" under "SUBODH SMRITY SOCIETY FOR RURAL DEVLOPMENT" REG. NO. – S/IL/01333 OF 2000-2001 SECRETARY – MRS. NILIMA DAS W/o – LATE TUSHAR KANTI DAS under group of educational occupancy at the premises on Plot- 287, JL. No. – 329, Khatian No.- 911, Mouza – Gograss in KhandakHhola Gram Panchayet, Under Block Panskura 1 No., P.O. – Raghunathbari, P.S. – Panskura, Dist. – Purba Midnapur, PIN. – 721634, W.B.

Memo NO. FSR/WBFES/HOW/700/15

This is in reference to your AIN 211892506300008208 dated 03-Sep-2025 regarding Fire Safety Certificate for an existing G+IV (Block-B as per plan) storied building in the name & style of "DHYANESWAR SUBODH ACADEMY" under "SUBODH SMRITY SOCIETY FOR RURAL DEVLOPMENT" REG. NO. – S/IL/01333 OF 2000-2001 SECRETARY – MRS. NILIMA DAS W/o – LATE TUSHAR KANTI DAS under group of educational occupancy at the premises on Plot- 287, JL. No. – 329, Khatian No.- 911, Mouza – Gograss in KhandakHhola Gram Panchayet, Under Block Panskura 1 No., P.O. – Raghunathbari, P.S. – Panskura, Dist. – Purba Midnapur, PIN. – 721634, W.B. .

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

However, to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008208

1. All the Fire Safety Recommendation which was issued by this office vide memo no.- FSR/WBFES/HOW/700/15, dt.- 08.04.2025 to be followed strictly at all time.
2. Driveway must be free from any type of obstruction for easy movement of fire appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
4. To eliminate risk of fire hazards, Good House Keeping both for inside and outside of the building shall be strictly maintained.
5. Electrical wiring of the whole building shall have to be carefully checked for any wire and tear in them, Particularly lines above false ceiling & ducts. Electrical safety Audit to be conducted positively by 31st March in every year.
6. A fire control room including a CCTV system will have to be maintained, which observe all floor of the building.
7. The notice of fire fighting and Evacuation from the shall be prepared and displayed at all venerable of the building.
8. The employees and security staff, shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of fire and testing.
9. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. Electrical installation room shall be protected with automatic CO2 or D.C.P. Fire extinguishers confirming I.S. Specification.
11. Unauthorized cooking arrangement in any floor of the hotel building except kitchen by using L.P.G., Kerosene etc. shall not be permitted and Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
12. Arrangement shall have to be made for regular checking, testing and maintenance of all fire fighting installation in the building to keep them in perfectly good working condition at all the items.
13. Periodical flashing of water in the Hose reel hose pipe line shall made to maintain the efficiency working performance of above mention system.
14. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
15. This certificate valid for 03 year from the date of issuance of this certificate.

A renewal certificate is to be obtained in every three year from the Director General, West Bengal Fire & Emergency Services for performance of all the life & fire safety arrangements and installations of the building.

Memo No.:FSR/WBFES/HOW/700/15

Valid Upto : 17-Dec-2028

Signature Not Verified

Digitally Signed.
Name: Bam Kumar Chowdhury
Date: 19-Dec-2025 18:29:02
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008208